

**(Code Change 780CMR919.7-3-14-06E1)**

**Amend Section 919** by adding a new Section, 919.7 that reads:

**919.7 Carbon Monoxide alarms:** Carbon monoxide alarms are required in R-2, R-3, R-4 and R-5 USES in accordance with the applicable requirements of 527 CMR and/or 248 CMR.

**Defense:** C.123 of the Acts of 2005 empowers the Board of Fire Prevention Regulations to promulgate CO Alarm requirements; additionally, the Fuel Gas and Plumbing Code (248 CMR) has CO alarm requirements for gas-fired appliances that are side-vented.